



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Wonerh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Certificate of constancy of performance 0843-CPR-0140

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Protecta FR Board Penetration Seal Classified for use in flexible & solid walls and solid floors

A board used to seal around cables and metallic pipes to form a penetration seal to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services. Protecta FR Board is supplied coated on one face, referenced 1-S, or on both faces, referenced 2-S. The board or boards are then cut to allow the penetration of the required services, before being inserted into the aperture in the wall or floor.

placed on the market by

Polyseam AS
Ravneveien 7
Linnestad Næringsområde
N-3174 Revetal,
Norway

and produced in the factory

Polyseam Ltd, Shaw Park, Silver Street, Huddersfield, HD5 9AF, UK

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the ETAs:

ETA 13/0673

under system AVCP 1 for the performance set out in this certificate are applied and that

Protecta FR Board fulfils all the prescribed requirements for these performances.

This certificate was first issued on 5th August 2015 and will remain valid as long as the ETA remains valid and the manufacturing conditions in the plant or the factory production control itself are not modified significantly, unless suspended or withdrawn by the product certification body.

First issue date: 5th August 2015

Signature:

Chris Miles
for
UL International (UK) Ltd.



EC CERTIFICATE

Notified Body No. 0843

CPR Notified Body, UL International (UK) Ltd., Wonersh House, The Guildway, Old Portsmouth Road, Guildford, Surrey, GU3 1LR, United Kingdom

Annex: Detailed information sheet

Certificate Number: 0843-CPR-0140

Product/Device description:

Protecta FR Board

Applicant designation:

Polyseam AS
Ravneveien 7
Linnestad Næringsområde
N-3174 Revetal,
Norway

Product Information:

Protecta FR Board

The referenced product complies with:

A – All the relevant requirements as per ETA 13/0673 issued 5th August 2015

A handwritten signature in blue ink, appearing to read 'Chris Miles'.

Chris Miles
for
UL International (UK) Ltd.